

Mr. Patrick H. Cahill
Wabash Valley Asphalt, LLC
P.O. Box 8297
Terre Haute, IN 47807

June 21, 2001

Re: 167-14425-00114
Third Administrative Amendment to
FESOP 167-9883-00114

Dear Mr. Cahill:

Wabash Valley Asphalt was issued a permit on February 2, 1999 for the operation of a stationary drum mix asphalt plant. Wabash Valley Asphalt also received a significant permit revision on July 26, 2000, a first administrative amendment on August 18, 1999, and a second administrative amendment on April 25, 2001. Two (2) other Administrative Amendments had been processed for a portable asphalt facility (FESOP 021-6044-03274) which is no longer located in Vigo County. A letter requesting the following additions was received on May 25, 2001: a 14,000 gallon fuel oil tank, a 9,000 gallon fuel tank, and a 8,000 gallon fuel tank. The 9,000 and 8,000 gallon fuel tanks are covered under the insignificant activities. Pursuant to the provisions of 326 IAC 2-8-10 the permit is hereby administratively amended as follows:

Wabash Valley Asphalt, LLC is currently utilizing their option to burn #4 fuel oil in lieu of natural gas as an alternate fuel. To effectively utilize this option, a larger fuel tank was required. Therefore, the addition of the 24' tall, 10' diameter steel tank with a 14,000 gallon capacity.

SECTION D.2 FACILITY CONDITIONS

Facility Description [326 IAC 2-8-4(10)]

Two (2) above ground, horizontal storage tanks used for storing AC 20, tank ID's: 9 and 9B, tank diameters: 11.5 feet and 11.0 feet, respectively, tank lengths: 32.0 feet and 32.5 feet, respectively, tanks volume: 2280 cubic feet each, annual throughput: 630,000 gallons per year each, tanks capacity: 20,000 gallons each. The tanks contain one (1) stack each, stack ID's: SV3 and SV5, respectively.

One (1) above ground, vertical storage tank used for storing AC 20, tank ID: 9A, tank diameter: 12.0 feet, tank height: 33.0 feet, tank volume: 2280 cubic feet, annual throughput: 630,000 gallons per year, tank capacity: 20,000 gallons. The tank contains one (1) stack, stack ID: SV4.

One (1) above ground, vertical storage tank used for storing #4 fuel oil , tank ID: 10, tank diameter: 10.0 feet, tank height: 24.0 feet, tank volume: 1885 cubic feet, annual throughput: 600,000 gallons per year (maximum), tank capacity: 14,000 gallons. The tank contains one (1) vent.

Reviewer: Darren Woodward

Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

D.2.1 That storage tanks (ID#s: 9, 9A, 9B, and **10**) shall comply with the New Source Performance Standards (NSPS), 326 IAC 12 (40 CFR Part 60.116b only, Subpart Kb). 40 CFR Part 60.116b requires the permittee to maintain accessible records showing the dimension of each storage vessel and an analysis showing the capacity of the storage vessel. Records shall be kept for the life of the storage tanks.

All other conditions of the permit shall remain unchanged and in effect. Please attach a copy of this amendment and the following revised permit pages to the front of the original permit.

This decision is subject to the Indiana Administrative Orders and Procedures Act - IC 4-21.5-3-5. If you have any questions on this matter, please contact Darren Woodward, at (812) 462-3433, ext. 15.

Sincerely,

George M. Needham
Director
Vigo County Air Pollution Control

DKW

cc: IDEM - Mindy Hahn
IDEM - Winter Bottum

**FEDERALLY ENFORCEABLE STATE
OPERATING PERMIT (FESOP)
OFFICE OF AIR MANAGEMENT
and
VIGO COUNTY AIR POLLUTION CONTROL**

**Wabash Valley Asphalt Co., LLC
5600 East Margaret Avenue
Terre Haute, Indiana 47808-8297**

(herein known as the Permittee) is hereby authorized to operate subject to the conditions contained herein, the source described in Section A (Source Summary) of this permit.

This permit is issued in accordance with 326 IAC 2 and 40 CFR Part 70 Appendix A and contains the conditions and provisions specified in 326 IAC 2-8 and 326 IAC 2-1-3.2, as required by 42 U.S.C. 7401, et. seq. (Clean Air Act as amended by the 1990 Clean Air Act Amendments), 40 CFR Part 70.6, IC 13-15 and IC 13-17.

Operation Permit No.: F167-9883-00114	
Issued by: George M. Needham, Director Vigo County Air Pollution Control	Issuance Date: February 2, 1999

First Administrative Amendment, 167-11246, issued on April 18, 1999 (Page(s) Affected: Page 29)
Second Administrative Amendment, 167-13897, issued on April 25, 2001 (Page(s) Affected: Page 1)

Third Administrative Amendment 167-14425	Pages Affected: Page 30 of 38
Issued by: George M. Needham, Director Vigo County Air Pollution Control	Issuance Date: June 21, 2001

SECTION D.2

FACILITY CONDITIONS

Facility Description [326 IAC 2-8-4(10)]

Two (2) above ground, horizontal storage tanks used for storing AC 20, tank ID's: 9 and 9B, tank diameters: 11.5 feet and 11.0 feet, respectively, tank lengths: 32.0 feet and 32.5 feet, respectively, tanks volume: 2280 cubic feet each, annual throughput: 630,000 gallons per year each, tanks capacity: 20,000 gallons each. The tanks contain one (1) stack each, stack ID's: SV3 and SV5, respectively.

One (1) above ground, vertical storage tank used for storing AC 20, tank ID: 9A, tank diameter: 12.0 feet, tank height: 33.0 feet, tank volume: 2280 cubic feet, annual throughput: 630,000 gallons per year, tank capacity: 20,000 gallons. The tank contains one (1) stack, stack ID: SV4.

One (1) above ground, vertical storage tank used for storing #4 fuel oil, tank ID: 10, tank diameter: 10.0 feet, tank height: 24.0 feet, tank volume: 1885 cubic feet, annual throughput: 600,000 gallons per year (maximum), tank capacity: 14,000 gallons. The tank contains one (1) vent.

Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

- D.2.1 That storage tanks (ID#s: 9, 9A, 9B, and 10) shall comply with the New Source Performance Standards (NSPS), 326 IAC 12 (40 CFR Part 60.116b only, Subpart Kb). 40 CFR Part 60.116b requires the permittee to maintain accessible records showing the dimension of each storage vessel and an analysis showing the capacity of the storage vessel. Records shall be kept for the life of the storage tanks.